



WEBER STATE
UNIVERSITY

Pre-construction Prevention Plan Checklist

Permit # _____

Consistent with the Clean Water Act

Date: _____

Project Name: _____

Project Address: _____

Owner's Name & Address: _____

E-mail Address: _____ Phone: _____

Contractor's Name & Address: _____

E-mail Address: _____ Phone: _____

SWPPP Contact Name & Address: _____

E-mail Address: _____ Phone: _____

Phone _____

Total Area in in Acres and are to be

disturbed in Acres: _____

The applicant, or an applicant's designee, shall participate in the pre-construction site inspections.
Weber State University has the right to conduct a pre-construction site inspection in person or using an electronic site inspection tool.

Stormwater Pollution Prevention Plan Checklist

YES NO N/A

Does the SWPPP show the location of the SWPPP Board BMP?

Does the SWPPP show the location of the construction entrance/exit?

Does the SWPPP show a designated material storage area?

Does the SWPPP show the equipment wash out area?

Does the SWPPP include the location of concrete washout area?

Does the SWPPP include the location of the portable toilets?

Does the SWPPP include the installation of storm drain inlet protection

BMPs?

Does the SWPPP include the location of the perimeter storm runoff control

BMPs?

Does the SWPPP include the location of trash containers or trash

receptacles?

Does the SWPPP show the spacing and number of trash containers

provided?

Does the SWPPP include existing wetlands?

Does the SWPPP specify the percentage of area to be disturbed or cleared?

Does the SWPPP show exiting waters of the state located within 200 feet?

Does the SWPPP include a proposed phasing plan if the project will

be divided into several phases?

Does the SWPPP include the frequency of the street/ parking lot

sweeping?

Does the SWPPP include the frequency of litter collection?

Does the SWPPP include the number of inlet protection BMPs to be

installed during construction?

Does the SWPPP include the frequency of maintenance inspections

of the storm drain inlet protection BMPs?

I understand that this SWPPP template is required and will remain in effect until the entire project is

stabilized, including re-vegetation and the NOT has been filed and accepted. All control measures will be inspected at least bi-weekly by contractor and monthly for MS4 or within 24 hours of a storm event of .5 inches or more. Tracking onto roads will be cleaned up immediately. Written records of all inspections, changes to this plan, and failures of control devices will be kept. The contractor is required to train all subcontractors, vendors, delivery personnel, and others who will be working on the site. The contractor is responsible for compliance of the SWPPP for the entire site and duration of the project. I understand that a pre-SWPPP inspection will be needed before any work can commence and a NOT will be submitted when the project is finished.

Print Name _____

Signature _____

Date _____